

D1.13
Dec. 5, 2011

CONDITIONED SPACE

EXTERIOR

Note:
Closed-cell spray foam insulation
thickness to meet local code
requirements.
Minimum thickness of 2" (50mm) required
when installed as a vapor retarder.

